

COMMERCIAL & INDUSTRIAL FLOORING SOLUTIONS

Variation Advice Form PKFQA01

VA / SI No. : 009

PROJECT: NEW MAITLAND HOSPITAL

PKF PROJECT NO: 130504

Attention: James Smyth - Andrew McParland Date: 22.02.2021

Company: Multiplex From: Sara Vaninetti

Fax No.: Total pages (incl. this one): 1

Subject: Conversion of the CT subwait to an OPG Room – 01.07.370

DESCRIPTION OF VARIATION:

Uplifting: 2hrs x \$95.00 = \$190.00

Grind: 13.65m² x \$7.20 = \$98.28

Skim: 13.65m² x \$9.15 = \$124.90

Armstrong Plus: 11.57m² x \$52.96 = \$612.75

150mm Cove: 14.77lm x \$31.20 = 460.82

Armstrong Foothold: 0.88m² x \$72.76 = \$64.03

150mm Cove: 2.65lm x \$33.11 = \$87.74

Armstrong Wallflex: 24.03m² x \$74.50 = \$1,790.24

Protection: 12.45m² x \$1.94 = \$24.15

ESTIMATED COST IMPLICATION: \$ 3,452.91 + GST

ESTIMATED TIME IMPLICATION:

BACK UP DOCUMENTATION ATTACHED:

☒ Yes ☐ No

Site Instruction/Authority of Works previous issued

☒ Yes ☐ No

PKF NEW SOUTH WALES

Unit 9, 6 Gladstone Road, Castle Hill NSW
2154
Phone: 02 9899 6688 E-mail:
info@pkfgroup.com.au
Website: www.pkflooring.com.au
ABN: 64 082 896 722 ACN: 082 896 722

PKF QUEENSLAND

18B Windorah Street, Stafford QLD 4053
Phone: 07 3352 4888 E-mail:
qld@pkflooring.com
Website: www.pkflooring.com.au
ABN: 64 082 896 722 ACN: 082 896 722

PKF HOSPITALITY

Unit 9, 6 Gladstone Road, Castle Hill NSW
2154
Phone: 02 9899 6688 E-mail:
info@pkfgroup.com.au
Website: www.pkflooring.com.au
ABN: 64 082 896 722 ACN: 082 896 722

Summary Report

BVN Telephone +41 2 6267 7230
Facsimile +41 2 6267 7269
www.bvn.com.ch

REGISTRATION OF ARCHITECTS
MEMBERSHIP OF ARCHITECTS

6504 ASSE GALVIN
6556 NINTEN-NA ITO-MOSKY
7115 JULIAN ADIFON
7252 MATTHEW BLAIR
7351 PHILLIP ROSS-INGEN
9337 HANIS /CHOROT

INTELLECTUAL PROPERTY

COPYRIGHT © 1986 BY MICROSOFT CORPORATION. ALL RIGHTS RESERVED. THIS DOCUMENT IS THE PROPERTY OF MICROSOFT CORPORATION AND IS LOANED TO YOU BY MICROSOFT CORPORATION. IT IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT PERMISSION IN WRITING FROM MICROSOFT CORPORATION.

ISSUE	DATE	FOR
1	03/06/91	FOR INFORMATION
2	29/11/91	FOR INFORMATION
3	29/11/91	FOR INFORMATION
4	25/12/91	FOR INFORMATION
A	04/06/00	FOR CONSTRUCT
B	21/06/00	FOR CONSTRUCT
5	29/12/00	FOR INFORMATION
6	05/02/01	FOR INFORMATION
7	11/02/01	FOR INFORMATION
C	15/02/01	FOR CONSTRUCT

NOTE:
PLEASE NOTE THIS DRAWING
"OPG ROOM" REPLACES
DRAWING "WAIT-SUB-CT" AS
ROOM TYPE AND FUNCTION
HAS BEEN UPDATED AS PER
INSTRUCTION MPX-SI-0006-
AND RVLNG-CORR-0765R.

NOTE:
PLEASE NOTE THIS DRAWING
'OPG ROOM' REPLACES
DRAWING 'WAIT-SUB-CT' AS
ROOM TYPE AND FUNCTION
HAS BEEN UPDATED AS PER
INSTRUCTION MPX-SI-00064
AND RIA-LCCOR-007658

CLIENT
NSW Health
Infrastructure
MANAGING CONTRACTOR
MULTIPLEX
Built to outperform.
PROJECT MANAGEMENT
CBRE
PROJECT
NEW MALT AND HOSPITAL

PROJECT NUMBER
S1806011.000

GRAPHIC SCALE
0 250 500 2000
150mm

SCALE
1: 50 (A2 DO NOT SCALE)

DRAWN BY (B) CHECKED BY (E)

DESIGN STATUS

CONSTRUCTION DOCUMENTATION

DRAWING
MEDICAL IMAGING UNIT
GENERAL X-RAY, FLUORO & CPG
CPG ROOM

DRAWING NUMBER	ISSUE
----------------	-------

GIBMT LOCAL 2019BENLASH-00M-001-012 | eval 00_duan_boluo.c


Scale 1:150 (original drawing scale 1:50)

FRE SCHEDULE - 01-07-2018		
Code	Description	Dry Qty
F01-01-017	DISPENSER disposable bowl, triple - at 1350 to underside	1
F02-04-006	BH waste, drain, 20L	1
W00-01-017	WALL FRESH aspirator, vinyl, 150 to 3000 AFFL	3
M00-01-017		
F01-01-017	DISPENSER parchment hold - at 1350 to underside	1
F01-00-017	DISPENSER soap - at 1350 to underside	1
F01-01-017	HOLDER, document, A4 papers - at 1950 to top	1
F02-04-016	BH waste, gensta, type B	1
H00-01-017	BAGIN, handwear, Type 5	1
F01-01-017	DISPENSER, handwear, disposable, single use, nitrile	1

PFE SCHEDULE E - 01.07.370		
Code	Description	City/Cn
ELBO-001q	BUTTON emergency stop - mounted at 1450 to centre	
ELBO-012	SWITCH light, dimmer - mounted at 900 to centre	
ELBO-014	SWITCH light, dimmer - mounted at 1100 to centre	
ELCP-123	GPO: emergency power, single, wall mounted	
ELCP-208	GPO: buzze, wall mounted	
ELCP-223	GPO: emergency power, double, wall mounted	
ELCP-226	GPO: emergency power, double, wall mounted - at 1100 to centre	
ELPR-001	BCDY PROTECTED ELECTRICAL AREA	
ELPR-006	RCO residual current device	


[illegible]

NOTE:
1. NAME EQUIPMENT AND SERVICES BY NUMBERS TO BE FINAL USE



3D VIEW

 SCHEDULE UPDATED




DIANA


NOTES:
 * FILE TO BE READ IN CONJUNCTION WITH DRAWINGS EYV-APH-53-RDL53H-NL
 20001 AND 20015 AND WITH DRAWING EYV-APH-53H-A00-001
 * NOT ALL GROUP 3 ITEMS ARE TO BE MODIFIED. REFER TO ROOM DATA SHEET

- SO VIEW PROVIDED FOR INFORMATION ONLY - NOT TO BE USED FOR CONSTRUCTION PURPOSES
- FOR FINAL LOCATION AND QUANTITIES FOR NURSE CALL AND ACCESS CONTROL, SECURITY AND OTHERS (VARYING) PLEASE REFER TO THE EIC GEN. SPEC. SERIES AND THE EIC GEN. AND SPEC.


* REFER TO SHEET BYN-APP-SOA-100-001 FOR A LIST OF GENERAL REVISIONS THAT HAVE OCCURRED PER DRAWING ISSUE. WHICH ARE NOT CIRCLED ON THE SHEET.




ELEVATION:




ELEVATION




ELEVATION



ELEVATION



ELEVATION



□□

**FOR
CONSTRUCTION**