

SUNSHINE COAST
T 0431 803 337 | E sunshinecoast@westerapartners.com.au

BRISBANE
T 07 3852 4333 | E brisbane@westerapartners.com.au

GOLD COAST
T 07 5571 1599 | E goldcoast@westerapartners.com.au

NORTHERN NSW
T 02 6674 8047 | E nsw@westerapartners.com.au



www.westerapartners.com.au | ABN 52 097 417 975

Engineering Inspection Report

14841

Date: 24 [REDACTED] Our Reference: B17-198 Client: [REDACTED]

Project Description: 16x ATTACHED HOUSES. Project Contractor: [REDACTED]

Project Address: 72-74 HARLEN ROAD, SALISBURY.

Extent of Work Inspected and Comments:

INSPECTION OF BUILDING 1 RAFFLE POD SLAB REINFORCEMENT.

- REINFORCEMENT OK.

- ENSURE ALL LOOSE DEBRIS IS CLEARED BEFORE POUR.

- ENSURE ALL COVERS ARE ACHIEVED & MAINTAINED DURING POUR.

This report does not relieve the Builder of his responsibility to ensure that work will be carried out with due care and diligence to comply with the Contract documents.

Signature: [REDACTED]