

SUNSHINE COASTT 07 5391 3777 | E sunshinecoast@westerapartners.com.au**BRISBANE**T 07 3852 4333 | E brisbane@westerapartners.com.au**GOLD COAST**T 07 5571 1599 | E goldcoast@westerapartners.com.au**NORTHERN NSW**T 02 6674 8047 | E nsw@westerapartners.com.auwww.westerapartners.com.au | ABN 52 097 417 975

Engineering Inspection Report

16629

Date: 15 / [REDACTED] Our Reference: B17-198 Client: D [REDACTED] SUP.

Project Description: ATTACHED HOUSES Project Contractor:

Project Address: 72 HARLEN RD SALISBURY.

Extent of Work Inspected and Comments:

2,3,
FRONT PATIOS BUILDINGS 4,5,6 REO INSPECTION.

Generally good, please ensure:

- Finish charring slab reo;
- Ensure N/A trimmer to all edges;
- Ensure adequate cover to all reo.

Σ

This report does not relieve the Builder of his responsibility to ensure that work will be carried out with due care and diligence to comply with the Contract documents.

Signature: [REDACTED]