

CONTINUED... became distracted from his place of work leaving wires exposed. Mr White assuming the circuit board had been isolated came in to contact with the live wires and as a result died from electrocution and severe burns. Mr Henry Thomas of EliteForm was also exposed the event and suffered temporary flash blindness.