



JCU TIC




← SCAN TO LOAD THIS LOCATION


JCU Townsville Technology Innovation Complex

Wed, Aug 7, 2024

Summary (3)

Open 0 Ready to inspect 0 Work Done 0 In dispute 0 Closed 3

ID	Location	Issue Description	Assigned to	Due	Status
2190	JCU TIC	Defect: Fire labels in poor locationCan't read one FP 4 04 APlant room	VAE Group	2024/01/22	Closed
 Captured by: Ethan Wilson (BESIX Watpac) Date: Wed, Apr 10, 2024, 3:33:46 pm Status when added: Open  Captured by: Alan Leeder (BESIX Watpac) Date: Mon, Jan 15, 2024, 2:11:59 pm Status when added: Open  Captured by: Alan Leeder (BESIX Watpac) Date: Mon, Jan 15, 2024, 2:11:58 pm Status when added: Open					
1641	JCU TIC > Level 4	Defect: Fix damaged duct plant room	VAE Group	2023/11/30	Closed
 Captured by: Alan Leeder (BESIX Watpac) Date: Thu, Nov 23, 2023, 8:45:56 am Status when added: Open  Captured by: Ethan Wilson (BESIX Watpac) Date: Wed, Apr 10, 2024, 2:19:27 pm Status when added: Closed  Captured by: Alan Leeder (BESIX Watpac) Date: Thu, Nov 23, 2023, 8:45:57 am Status when added: Open					
904	JCU TIC	Defect: Access to fire dampers restricted review to ensure servicing can be achieved Ground floor	VAE Group	2023/06/01	Closed
 Captured by: Alan Leeder (BESIX Watpac) Date: Thu, May 18, 2023, 8:48:42 am Status when added: Open  Captured by: Alan Leeder (BESIX Watpac) Date: Thu, May 18, 2023, 8:48:42 am Status when added: Open  Captured by: Alan Leeder (BESIX Watpac) Date: Thu, May 18, 2023, 8:48:42 am Status when added: Open					



Captured by: **Alan Leeder**
(**BESIX Watpac**)

Date: **Thu, May 18, 2023,**
8:51:32 am

Status when added: **Open**