



JCU TIC


← SCAN TO LOAD THIS LOCATION

JCU Townsville Technology Innovation Complex

Wed, Aug 7, 2024

Summary (1)

Open 0 Ready to inspect 0 Work Done 0 In dispute 0 Closed 1

ID	Location	Issue Description	Assigned to	Due	Status
941	JCU TIC > Level 1 > X108 - CM1 - Communications	Defect: Level three comms room Insulation to be 50mm of fire collars	Tacoma Plumbing Nth Qld Pty Ltd	2023/06/29	Closed
 Captured by: Alan Leeder (BESIX Watpac) Date: Thu, Jun 22, 2023, 10:21:48 am Status when added: Open  Captured by: Alan Leeder (BESIX Watpac) Date: Thu, Jun 22, 2023, 10:22:45 am Status when added: Open  Captured by: Alan Leeder (BESIX Watpac) Date: Thu, Jun 22, 2023, 10:21:47 am Status when added: Open					