

SAFETY COMMITTEE SITE WALK INSPECTION

Safety committee member/site representatives

DATE: 01.02.23

NAME	COMPANY	TIME
Clinbn Guest	M ^c NAB	11:00AM
Adrian Wyatt	M ^c NAB	11:00AM
Dylan Nankervis	DYDA	11:00AM
Jordan Bull	CS	11:00am
Steve Plannq	Applied	11:00am
DARREN BAFIN	APEx	4:00 AM
Matt Sansom	firebar	11:00AM
Leon Raiton	Fitout	" "
Matt Henrich	TK TK	11:00am
Ben Griffin	AD Scaffolding	11:00

SCAFFOLD SOUL BOARD INSPECTION

LOCATION	WORK REQUIRED	ACCESS TO SCAFFOLD RESTRICTED? Y/N	TIME SCAFFOLD SAFE TO ACCESS
Perimeter	none	N	N/A

TEMP ELECTRICAL BOARD INSPECTIONS

TEMP BOARD NO.	LEVEL	ELECTRICALLY SAFE Y/N	TIME DEEMED SAFE TO USE
14, 15, 16	4	Y	N/A
11, 12, 13	3	Y	N/A
8, 9, 10	2	Y	N/A
5, 6, 7	1	Y	N/A
2, 3, 4	G	Y	N/A

SAFETY COMMITTEE SITE WALK INSPECTION

INSPECTION LOCATION

LEVEL / ZONE	HAZARD / TRADE	WORK REQUIRED	INITIAL
G	trip - MC/NAB	Pipe in walkway - mark up	
Level 4	fall object / AR	exclusion zones below / Hout	Q
Level 4	heat stress	Reviewed water pressure, no 11/re	Q
Level 3	exposure / TK	no stair closed sign	Q
All Areas	struck by / MC/NAB	Scaffold tie in walkway - abut box	
Level 3	info.	update loading bay sign	Q
Level 2	contaminant	at loading bay	
Level 2	Housekeeping TK	Sweep mb piles, clean up pile	Q
Level 1	Apex fall object	vertical stacking - secure door frame	Q
Level 1	lighting manhole	Consulted Comm, re around light and emergency backup	Q
Level 1	Silica Dust MC Brick	Corefill wanderers deck	
Level 1	lack of info MC/NAB	ladders 3m back	Q
Level 1	Dust MC	MC fill on scaffold	
Ground	exposure All trades	keep EWP's clear from access ways	Q
Ground	access TK	Build ramp for hoist access	
Level 1	fall Apex	loose props - see TK / MC/NAB	Q
All	struck by	approval before entering loading zone authorized person's only	Q
All	slips, trips, falls	Keep walkways clear from tools and materials	Q