

Adrian Wyatt

From: Shawn Brosnan <shawn.brosnan@formiga1.com>
Sent: Thursday, 23 February 2023 2:22 PM
To: Adrian Wyatt
Cc: Levi Carsburg; Ashley Lowe; Alex Ham; Michael Hemmings; Jackson Woollett
Subject: Re: Rockpool Pelican Waters Change of Door swing

Thanks Adrian

The doors appear to be internal door and as such only require PWD access/circulation as designed and door hardware compliant to BCA Clause D2.21 (The same requirements no matter which way the door swings)

I hope this helps clarify the design requirements.

Kind regards,



Shawn Brosnan
General Manager

0423 089 600
shawn.brosnan@formiga1.com

Global Office

Phone: 02 9597 9952
Level 2, 10 King Street,
ROCKDALE NSW 2216

On Thu, Feb 23, 2023 at 12:31 PM Adrian Wyatt <Adrian.Wyatt@mcnab.net.au> wrote:

Afternoon Shawn,

See below emails from our client, They would like to change the swing of a door on ground floor.

Can you please review before we proceed and ensure it is acceptable from a compliance side.

Thank you.

Regards,

Adrian Wyatt
Site Manager

07 5408 2300 | 0421 618 310

adrian.wyatt@mcnab.net.au

Level 5, Tower 2, Kon-Tiki Building
55-59 Plaza Parade MAROOCHYDORE QLD 4558
PO Box 5054, WEST END QLD 4101



 safety first

quality always

From: Roman Summers <roman.summers@rockpoolrac.com>

Sent: Monday, 6 February 2023 3:26 PM

To: Callum Bell <Callum.Bell@mcnab.net.au>; Levi Carsburg <Levi.Carsburg@mcnab.net.au>; Michael Hemmings <michael@gigarchitects.com.au>

Cc: Ashley Lowe <Ashley.Lowe@mcnab.net.au>; 22066 McNab - Rockpool Pelican Waters <mailbox.22066@mcnab.net.au>; Bill Summers <bill.summers@rockpoolrac.com>; Adrian Wyatt <Adrian.Wyatt@mcnab.net.au>

Subject: Re: Pelican Waters Nursecall Review

Hey All,

The admin door should have access control. To match what we have at Morayfield and Carseldine.

A wireless handle would be fine for this.

Also, can we flip which way the admin door opens? This would make it easier in the event we wish to hold this door open during certain operating hours.

I'm assuming the reception door would need to be an electric strike as per Morayfield as it needs to unlock in event of fire, and we don't wish public to access admin via jumping over reception.

Boh admin door to remain wireless access control, as we don't want kitchen staff wandering into admin.

Thanks,

Roman Summers

 0402 648 885

Development Manager



✉ roman.summers@rockpoolrac.com
☎ 07 3553 1199

www.rockpoolrac.com

Rockpool: 'rok,pu:l / n
safe, secure, inclusive
reflective, contemplative
vibrant with life, habitat

We respectfully acknowledge the Gubbi Gubbi people's country and Turrbal people's country on which we live and work. We pay our respects to the traditional custodians and Elders past, present and emerging.

PLEASE CONSIDER THE ENVIRONMENT BEFORE PRINTING.

This message is intended only to be read or used by the addressee. It is confidential and may contain legally privileged, proprietary, or otherwise private information. If you are not the addressee indicated in this message (or responsible for delivery of the message to such person), you may not copy or deliver this message to anyone. We'd be grateful if you would kindly notify the sender immediately and delete the original.

From: Callum Bell <Callum.Bell@mcnab.net.au>

Sent: Monday, 6 February 2023 13:37

To: Levi Carsburg <Levi.Carsburg@mcnab.net.au>; Michael Hemmings <michael@gjgarchitects.com.au>; Roman Summers <roman.summers@rockpoolrac.com>

Cc: Ashley Lowe <Ashley.Lowe@mcnab.net.au>; 22066 McNab - Rockpool Pelican Waters <mailbox.22066@mcnab.net.au>; Bill Summers <bill.summers@rockpoolrac.com>; Adrian Wyatt <Adrian.Wyatt@mcnab.net.au>

Subject: RE: Pelican Waters Nursecall Review

Roman just to be clear the admin and reception wall has been adjusted – below is the latest plan.

Do you want Wireless access on *both* admin doors?

