

```

preliminary drawing only

```

preliminary drawing only

EXTERIOR

EXTERIOR

Thermal insulation
Acoustic insulation
Fire Resistance

Diagram illustrating the components of a roof assembly:

- EXTERIOR
- ROOF SPACE
- Thermal insulation
- Acoustic insulation
- Fire Resistance

Total wall R value: As per JV-3 Report
As per acoustic report
N/A

CORRIDOR

ROOM

Thermal insulation
Acoustic insulation
Fire resistance

13mm Impactchek to 1200mm above FFL, 13mm Soundchek over
92mm yellow stud, 75mm Fibreglass insulation
13mm Soundchek (13mm W.R. Soundchek within wet areas. 9mm Villaboard within kitchen)

ENSUITE



VOID

Thermal insulation
Acoustic insulation
Fire Resistance

Wall incl insulation extends to u/s slab over. On Level wall & insulation extends from floor to min. 100mm above ceiling

13mm Aquacheck

64mm steel stud, 75mm Fibreglass insulation



EXTERIOR

INTERIOR

Thermal insulation
Acoustic insulation
Fire Resistance

m Plasterboard
 m furring channel
 m concrete block, core filled
 m furring channel
 m Plasterboard

9 637 879 228
27) 5520 1134

	Tender Issue	
	Amendment	
		Drawing Number
		20-12-A-6.20
Scale 1 : 10 @ A1 original		

The design and drawings for this project remains
the copyright of MPC Architecture Pty. Ltd. ACN 637879228

Notes:

Refer to Compartmentation & Exit plans - all smoke walls to extend to u/s slab / roof sheeting as applicable to comply with NCC.

Refer to Acoustic Report for acoustic requirements and details.

This wall type called up to corridor on ground level as well. Confirm Rw rating of this wall as Rw45 may not be required (its not required in the acoustic report)
Can we revert this back to WT70