

CPCCBC4006B

SELECT, PROCURE AND STORE CONSTRUCTION MATERIALS FOR LOW RISE PROJECTS

ASSESSMENT SUMMARY

The assessment activities for *CPCCBC4006B Select, procure and store construction materials for low rise projects* cover all aspects of the unit of competency required. To demonstrate competence in this unit, a participant must undertake all tasks and complete them satisfactorily and consistently. For Apprentices and Trainees, this includes employer completion of the Employer Record Book (ERB).

Participants must read all the information given before starting any assessment task. The assessment tasks are intended to be equitable, fair and flexible. If a participant has any questions or requires alternative arrangements to be made such requests should be directed to their Trainer/Assessor, who should note such arrangements in the 'Assessor Comments' on the affected assessment. If a participant feels they are not yet ready to be assessed, they should discuss their options with their Trainer/Assessor.

To satisfactorily complete the assessment, the participant is required to answer all questions correctly and demonstrate their skills to industry standards. If a participant does not answer some questions or perform some tasks, they will be deemed 'Not Satisfactory' for the task and 'Not Yet Competent' for the unit of competency. The Trainer/Assessor is able to provide the participant with additional information on interpreting the assessment outcomes and provide guidance on the participant's options. Should a participant still be deemed 'Not Satisfactory' they will have the opportunity to undertake a supplementary assessment or appeal the result.

By signing the cover page for each assessment item, the participant acknowledges they understand the assessment instructions and requirements and consent to being assessed. The participant also verifies and assures the RTO that the work submitted is their own work.

Participant Name	Melissa Parsons
------------------	-----------------

Task	Assessment Results	
Theory Exam	☐ Satisfactory	☐ Not Yet Satisfactory
Practical Assessment	☐ Satisfactory	☐ Not Yet Satisfactory
Outcome for Unit of Competency	☐ Competent	☐ Not Yet Competent

Assessor Name	
Assessor Signature	
Unit Competence Determination Date	Click here to enter a date.

CPCBC4006B


SELECT, PROCURE AND STORE CONSTRUCTION MATERIALS FOR LOW RISE PROJECTS

THEORY EXAM INSTRUCTIONS

- This exam will occur under standard assessment conditions.
 - An oral examination may be allowed under certain circumstances, whereby the Participant's answers will be documented by a party other than the Participant. This must be acknowledged in writing (e.g. FT001 and Assessor Comments)
- Participants must provide enough detail in their responses to demonstrate their knowledge and skills.
- Please fill in the details below, providing your name, signature and date of assessment.
 - Your signature acknowledges that this is your own work.
- Assessors are to complete marking in pen of a different colour to the Participant.
- If a Participant initially answers a question incorrectly but modifies their response, they must follow the instructions below:
 - If a Participant changes their response in writing, they must put their initials next to the written change.
 - If a Participant changes their response verbally, this must be noted on the exam paper by the assessor.

Participant name Mellissa Parsons

Participant signature



Date 11/10/2021

Assessor name _____

Assessor signature _____

Date Click here to enter a date.

Number of questions	Number of questions answered correctly	Task outcome (Tick)	
		Satisfactory	Not Yet Satisfactory
44		☐	☐

Q1. Which of the following documents and/or people would you refer to when selecting materials for a building project? Tick all that apply.

Answer

Choice	Possible Answers
☒	Australian Standards
☒	Contract
☒	Drawings
☐	Manufacturer
☒	National Construction Code
☒	Specifications
☐	Tolerances

☐

Q2. Identify the Volume and Parts of the NCC that relate to suitability of materials for Classes 1 and 10, and Classes 2 to 9.

Answer

Classes 1 and 10	Classes 2 to 9
Volume 2 Part A5	Volume 1 Part A5

☐

Q3. Identify the assessment methods used to verify a performance solution.

Answer

Evidence of suitability Verification method Expert judgement Comparison with the deemed to satisfy provisions
--

☐

Q4. Which of the following solutions for material selection often references the Australian Standards? Tick your response.

Answer

Choice	Possible Answers
☒	Deemed-to-Satisfy solution
☐	Performance solution

☐

Q5. Identify five (5) materials commonly used for *low rise buildings* in your region. For each material, identify the following:

- Its name
- Properties of the material

Answer

#	Material name	Properties
1	Concrete	Combination of a binder and aggregate (gravel and sand)
2	Blocks	Made from clay, shale or mud
3	Glass	Mixture of sand and silicates
4	Plasterboard	Plaster between paper liners
5	Vinyl flooring	Coloured polyvinyl chloride chips (PVC)



- Q6. For each of the materials in Q5. identify the following:
- Quality of the material (i.e. durability, serviceability, cost effectiveness)
 - Compatibility and non-compatibility of the material (i.e. what it would/would not be suitable for)

Answer

#	Quality	Compatibility
1	longevity formability easability of transport keeping costs down	Compatible with steel rods & bars to strengthen for driveways, house slabs and blockfill
2	Cheap flame retardant	Great for houses
3	brittle keep heat out	Letting light in but keeping elements out Windows, doors, walls and roofs
4	Fire resistance Humidity resistant Acoustic insulation	Interior walls and ceilings Not good near open fire or temps above 52 deg celcius
5	Moisture resistance Waterproof Durable Quick and easy to install Easy to clean	Suitable in all areas of a build Perfect for daycare Lay direct on top of cement



Q7. Identify five (5) physical characteristics that may be considered when evaluating potential building materials.

Answer

- Strength
- Moisture absorption
- Acoustic
- Density & specific gravity
- Electrical conductivity



Q8. Match the terms and definitions below by writing the appropriate letter next to each number in the centre column.

Answer

Term		Answers
1	Carbon footprint	1 -B
2	CO ₂ e	2 -E
3	Embodied energy	3 -A
4	Embodied water	4 -D
5	GHG	5 -C

Definition	
A	The amount of energy required to manufacture a product
B	Total GHD emissions produced during manufacture construction and use
C	Greenhouse gas emissions
D	The amount of water required to manufacture a product
E	CO ₂ equivalent tonnes emitted into the atmosphere



Q9. Which of the following materials would be considered as 'low energy content'? Tick all that apply.

Answer

Choice	Possible Answers
☐	Bricks
☒	By-products of other industrial processes
☐	Cement
☐	Glass
☐	Metals
☐	Plastics
☐	Sand
☒	Stone
☒	Timber



Q10. Refer to the table below and identify the wall material type that has the smallest embodied energy and emission impact.

COMPONENT	kWh/ m2 indoor floor area	Kg CO2e/ m2 indoor floor area
Floor suspended slab 114 - 117 mm	208	68
Floor suspended timber on stumps	76	26
ROOF		
Roof steel frame colorbond steel or tile	209	72
Roof timber frame colorbond steel or tile	143	47
WALLS		
Walls double brick; s/b interior	312	103
Walls brick veneer timber frame	204	67
Walls timber frame fibro clad	61	20
Walls steel frame fibro clad	90	30
Walls Timber frame timber clad	68	23
Walls pre-cast concrete	264	88
Walls concrete block	160	53
OTHER , APPLICABLE TO ALL HOMES REGARDLESS OF TYPE		
Construction, admin, transport, other materials such as copper pipes, glass, aluminium	406	144
Floor coverings assume approx. 50% ceramic tile 50% polypropylene carpet	61	20
Fittings, fixed appliances built in \$ bathroom, kitchen, w/robes	96	43
ADDITIONS	kWh/ m2 area or m length	Kg CO2e/ m2 area or m length
Roofed open areas - alfresco / porch / verandah / carport	352	117
Garage single brick or cavity walls, concrete slab, steel or tile roof	675	219
Open Carport	352	117
Fence brick or metal (per metre length, assuming 1.5 m height)	186	61
Paving (brick or concrete)	96	32
Pool (concrete below ground)	534	198

Answer Timber frame fibro clad



Q11. Identify the Volume and Parts of the NCC that relate to energy efficiency of materials for Classes 1 and 10, and Classes 2 to 9.

Answer	Classes 1 and 10	Classes 2 to 9	☐
	Volume 2 Section 2 part 2.6 Section 3 part 3.12	Volume 1 Section J Part J0-8	

Q12. Identify the relevant section of the Standards and Tolerances Guide and the associated Australian Standard that addresses residential slabs and footings.

Answer	Standards and Tolerances Guide	Australian Standard	☐
	Section 3	AS2870-2011	

Q13. Identify the relevant section of the Standards and Tolerances Guide and the associated Australian Standard that addresses roof tiles.

Answer	Standards and Tolerances Guide	Australian Standard	☐
	Section 7.4	AS2050-1995	

Q14. Identify the Volume and Parts of the NCC that relate to safety barriers for swimming pools for Classes 1 and 10, and Classes 2 to 9.

Answer	Classes 1 and 10	Classes 2 to 9	☐
	Volume 2 3.10.10	Volume 1 Section G Part G1.1	

Q15. In some states, barriers and fences for swimming pools are not entirely regulated by the NCC, as noted in the Ancillary Provisions and State and Territory Variations. Identify the applicable Act and Regulation that regulate safety barriers for swimming pools in your jurisdiction.

Answer	Building Act 1975 Building regulation 2006	☐
---------------	---	--------------------------

Q16. Identify the Australian Standard that relates to safety barriers for swimming pools.

Answer

AS1926
Part 1 2012
Part 2 2007

☐

Q17. True or False (Tick your response): According to the Standard in Q16. all gates must be fitted with a self-closing device that will return the gate to a closed position from any position without the use of manual force.

Answer

☒	True
☐	False

☐

Q18. Identify the Volume and Parts of the NCC that relate to fire-resistance of building elements for Classes 1 and 10, and Classes 2 to 9.

Answer

Classes 1 and 10	Classes 2 to 9
Volume 2 Schedule 5 Part A5	Volume 1 Section C

☐

Q19. Identify the Australian Standard that relates to fire-resistance tests for elements of construction.

Answer

AS1530
Part 4 2014

☐

Q20. For all NCC Classes, where the ground or subfloor space is excessively damp or subject to frequent flooding, which durability class must the subfloor framing must be used where above ground?

Answer

Class 1 or 2 timbers or H3 preservative treated timbers in accordance with AS1684.2, AS1684.3 or AS1684.4

☐

Q21. Identify the Australian Standards that must be observed when meeting the requirements for Q20.

Answer

AS1684.2
AS1684.3
AS1684.4

☐

Q22. True or False (Tick your response): Where materials are not used as intended (or without considering NCC requirements), this can make a significant difference to the life or serviceability of the structure.

Answer

☒	True
☐	False

☐

Q23. Explain why durability and serviceability impact on the cost effectiveness of chosen materials.

Answer

They go through testing to ensure they meet with Australian Standards

☐

Q24. Provide an example of short term degradation of materials and describe its effects on a building on structure.

Answer

Timber – untreated and exposed to weather can split / crumble / rot need to be replaced more frequent or make building unsafe

☐

Q25. Provide an example of long term degradation of materials and describe its effects on a building on structure.

Answer

Copper when exposed to oxygen & air corrode very slowly
Discoloration or corrosion will require replacement eventually

☐

Q26. You have spoken to a supplier who has indicated that some of the client's desired materials are unavailable. When considering alternative building materials what must be taken into consideration (i.e. other than the client's requirements)?

Answer

Performance test
Efficiency
Environmentally sustainable
Cost effective
Transportation
Compatibility
Life-cycle

☐

Q27. Identify two (2) things that you should look for when receiving a delivery of materials.

Answer

Condition of delivery
Correct quantity

☐

Q28. If you encounter issues with delivery, what two (2) options do you have?

Answer ☐ Accept with conditions
Reject delivery

**Q29. Which of the following should be assessed before shifting materials?
Tick all that apply.**

Answer ☐

Choice	Possible Answers
☒	What needs to be relocated (e.g. size, weight)
☒	The relocation area, site layout and obstacles
☒	Distance and time to relocate load
☒	Whether a team is available and/or appropriate
☒	Whether PPE must be worn (e.g. for hazardous materials)


Q30. What document should you refer to for guidance on how to handle and store hazardous chemicals?

Answer ☐ Safety data sheet

Q31. Name three (3) ways you can reduce the risk of injury if a load is too heavy for one person to carry, push or pull.

Answer ☐ Mechanical aid
Lighten load
Team lift

- Q32. In the diagram below a person is lifting a tool box.
Filling in the table, indicate how each body part should be used/placed.



Answer

Area of body (Letter)	How it should be placed
D	Level
A	Upright
F	Good grip
B	Natural curve
E	Bent
C	Flat, facing load

☐

- Q33. How should construction materials and components be handled?
Tick all that apply.

Answer

Choice	Possible Answers
☒	Sorted to suit material type and size, separating hazardous material
☒	Stacked or stockpiled for ease of identification and retrieval
☐	Stored in access ways for ease of retrieval
☒	Stored clear of access ways
☒	Handled and positioned ready for installation

☐

- Q34. Identify the Australian Standard that relates to the storage and handling of LP gas.

Answer AS/NZ 1596:2008

☐

Q35. List one (1) testing method for each of the building materials listed below.

Answer	Material name	Properties	☐
	Concrete	Cylinders of concrete are taken during delivery & tested at 7, 14 & 28 days for the tension, compression & bending	
	Metals	Repeated testing to test the strength under load several hundred or thousands of times	
	Timber	Stress grading – visual for domestic Stress grade machine for large quantities	

Q36. What Code gives detailed tables which state the required grade of timber for specific sizes and uses?

Answer ☐

Q37. Name two (2) ways that defects may be seen in timber.

Answer ☐

Q38. Identify two (2) tests that may be performed to determine the durability of stone.

Answer ☐

Q39. Name two (2) ways that defects may be seen in stone.

Answer

Visually – cracks, colour, grain size
Staying wet

☐

Q40. True or False (Tick your response): Under a contract, builders and other specialist tradespersons are the ones most likely to rectify or remedy problems that arise from incorrect installation, application or placement of materials.

Answer

☒	True
☐	False

☐

Q41. Name two (2) established methods that may be used to preserve timber.

Answer

Chemical
Mechanical

☐

Q42. Identify two (2) established methods that may be used to protect ferrous metals.

Answer

Paint system
Galvanising

☐

Q43. Explain why the corrosion resistance of non-ferrous metals is superior to that of ordinary steel.

Answer

Items are coated in salt or a ceramic coating of oxide
Which protects from further corrosion

☐

**Q44. When should aluminium be coated with bituminous paint?
Tick all that apply.**

Answer

Choice	Possible Answers
☐	At all times
☒	When it is buried in soil
☒	When it comes in contact with chemical materials
☒	When it is immersed in water
☐	When it is used on bitumen

☐

CPCCBC4006B

SELECT, PROCURE AND STORE CONSTRUCTION MATERIALS FOR LOW RISE PROJECTS

PRACTICAL ASSESSMENT INSTRUCTIONS

- The following practical assessment will require the Participant to complete work related activities.
- The Assessor will conduct observations of the Participant's work to determine whether they display sufficient practical skills and knowledge.
- Please fill in the details below – providing your name, signature and date of assessment.
 - The Participant's signature acknowledges that the Assessor provided clear instructions and the Participant understood what was required to complete this assessment.
- The Assessor may substitute a Practical Task with an alternate task of equal value.
 - Alternate tasks must be fully documented by the assessor in the Assessor Comments area.

Participant name Mellissa Parsons

Participant signature _____

Date 11/10/2021

Assessor name _____

Assessor signature _____

Date Click here to enter a date.

Task	Task outcome (Tick)	
	Satisfactory	Not Yet Satisfactory
Task 1 (Occasion 1)	☐	☐
Task 1 (Occasion 2)	☐	☐

ASSESSOR COMMENTS	

CPCBC4006B

SELECT, PROCURE AND STORE CONSTRUCTION MATERIALS FOR LOW RISE PROJECTS

Practical Task 1 (2X)		
Description of task: On two (2) occasions, a suitable observer is to verify the participant's ability to supervise systems through which materials are selected, acquired and stored on site for the following projects: Occasion 1: Construction classified as Class 1 and 10 construction Occasion 2: Construction classified in Classes 2 to 9 with a gross floor area not exceeding 2000 square metres, not including Type A or Type B construction The participant is to gather evidence of how they have completed each component of the Practical Task, which is to be submitted with this Practical Assessment sheet. Evidence to be submitted may include: - Copy of PO sent to site team for materials. - Email correspondence sighting need for materials, delivery of materials and storage of materials (if relevant). The observer is to provide detailed comments on the tasks completed by the participant. The assessor is to verify the observer's comments in the Assessor Comments section, and provide the Practical Assessment outcome on the front cover of this document.		
Resources required: Computer, Building Contract, Drawings, Specifications, Building materials (including timber, and ferrous and non-ferrous metal).		
Assessment of task		
Name of participant:	Mellissa Parsons	
Name of observer:	Daniel Ogden	
Role of observer (Confirm suitability to sign)	Senior Contracts Administrator	
Email address of observer	dogden@rcq.net.au	
Signature of observer:		
Date:	10/10/2020	
When completing the task, did the participant:	Tick if satisfactorily completed. Provide comments if left unticked.	
	1 st Occasion	2 nd Occasion
1 Evaluate building materials		
1.1A. Identify suitability of materials commonly used in the region for low rise buildings.	☒	☐
1.1B. Through research and testing, identify properties of different materials, their quality and compatibility and non-compatibility and maintain effective sampling and organisational record-keeping processes.	☒	☐
1.1C. Identify the environmental impacts of different materials.	☒	☐
1.1D. Identify the impact of allowable tolerances on the conversion of naturally occurring materials.	☒	☐

1.1E.	Identify and check tolerances for installing and assembling materials with regard to the nature of the work being performed and the requirements of relevant construction industry Australian standards.	☒	☐
2 Material selection			
1.2A.	Select materials structurally adequate and appropriate for the building system specified in the contract, drawings and specifications.	☒	☐
1.2B.	Select materials after considering: • Safety • Required fire resistance rating • Suitability to the application • Durability • Serviceability and cost effectiveness • Compliance with NCC, legislation, regulations and Australian Standards	☒	☐
1.2C.	Consider short and long-term degradation of materials in relation to the building's proposed life cycle.	☒	☐
1.2D.	Select and evaluate alternative materials, if specified materials were unavailable or unsuitable – justifying decisions to regulatory authorities, as necessary	☒	☐
1.2E.	Finalise selection of materials in accordance with contractual requirements and in consultation with relevant professionals and the client, compiling results in a report.	☒	☐
1.2F.	Effectively communicate using the following methods: • Language/concepts appropriate to cultural differences • Non-verbal communication	☒	☐
3 Supervising materials on site			
1.3A.	Determine limitations and effects of transportation on material and components, taking action in potentially damaging circumstances.	☒	☐
1.3B.	Ensure materials were correctly and safely handled on site using appropriate equipment and safe work practices.	☒	☐
1.3C.	Communicate with manufacturers and suppliers to ensure materials are stored in accordance with specifications and Australian standards.	☒	☐
1.3D.	Implement processes for inspecting all materials delivered on site for naturally occurring and/or manufactured defects before installation.	☒	☐
1.3E.	Ensure personnel were aware of actions to be taken in the case of defects caused by incorrect installation, application or placement.	☒	☐
1.3F.	Preserve and protect timber and ferrous and non-ferrous metal used in the construction process.	☒	☐
The Participant's performance was: ☒ Satisfactory ☐ Not Satisfactory			

OBSERVER COMMENTS

Occasion 1: Kirwan Ambulance Station, Class 5, 990m2

Occasion 2: 70 The Strand, Class 6, Type C, 869m2